



133-782  
December 6 2018



# Fireeye<sup>®</sup> FLAME SCANNERS

**UV Non Self-Checking Scanner Models:  
UV7R4**

---

## ERRATA SHEET 133-782

### HAZARDOUS AREA CLASSIFICATION FOR FIREYE SCANNERS

In order to maintain the hazardous area classification rating (see below) of the UV7R4-EX scanner, the UV7R4-EX flame scanner **MUST BE MOUNTED** on a 1/2 inch sight pipe on the boiler.

The EX housing itself supplied with the UV7R4-EX has a Class I Division 1 rating. To comply with a Class I Division 1 rating, remove and discard the plastic compression fittings and install the wiring in conduit with fittings suitable for the hazardous location application.

#### Hazardous Location:

Class I, Div 1, Groups B, C, D.  
Class II, Div 1, Groups E, F, G.  
Class III

