

# FEATURES & SPECIFICATIONS

**INTENDED USE** — For applications that require the clean appearance of a low-profile, brightnesscontrolled wraparound. Provides broad distribution of light for offices, schools and corridors. Certain airborne contaminants can diminish integrity of acrylic. <u>Click here for Acrylic Environmental</u> Compatibility table for suitable uses.

Attributes: Linear side prisms control brightness, pyramidal bottom prisms minimize lamp image. Diffuser hinges open from either side for easy maintenance. Full depth, white enamel end plates.

**CONSTRUCTION** — Die-formed from code gauge cold-rolled steel. Channel cover snaps into place without the use of tools. Full end cap factory installed to reduce job site labor. Diffuser is extruded clear acrylic. Finish: Five-stage iron-phosphate pretreatment ensures superior paint adhesion and rust resistance.

Finished with high-gloss, baked white enamel.

**ELECTRICAL** — Thermally protected, resetting, Class P, HPF, UL listed, CSA Certified ballast is standard. Energy saving and electronic ballasts are sound rated A.

Luminaire is suitable for damp locations. AWM, TFN or THHN wire used throughout, rated for required temperatures.

**INSTALLATION** — For surface or stem mounting, individual or row installation.

LISTINGS — UL Listed (standard). Optional: CSA or cUL. Mexico NOM.

Specifications

14-3/16 (36.0)

2-3/4 (7.0)

All dimensions are inches (centimeters) unless otherwise indicated.

ORDERING INFORMATION

T8 Length: 48 (121.9)

Width:

Height:

T5 Length: 46-1/2 (118.1)

WARRANTY — 1-year limited warranty. This is the only warranty provided and no other statements in this specification sheet create any warranty of any kind. All other express and implied warranties are disclaimed. Complete warranty terms located at: <u>www.acuitybrands.com/support/customer-support/</u> terms-and-conditions

Note: Actual performance may differ as a result of end-user environment and application. Specifications subject to change without notice.


> 13-3/8 (34.0) 1-7/16 (3.7) Æ. 2-3/4 (7 0) 3-5/8 (9.2) 3-5/8 (9.2) 14-3/16 (36.0)

Catalog

Number

Notes

Туре





For shortest lead times, configure product using standard options (shown in bold).

Square-Basket Wraparound

T5 and T8 WIDE BODY 4' lenath 2 or 4 lamps

SK





### Example: SB 4 32 MVOLT GEB10IS

Series		Number of lamps	Lamp ty	pe	Voltage	Options	
	ps, 14-3/16" wide ps, 14-3/16" wide	2 4	<b>32</b> 28T5 54T5HO	32W T8 (48") 28W T5 (46-1/2") 54W T5HO (46-1/2")'	120 277 347 <b>MVOLT</b> <sup>2</sup> Others available.	1/4 GEB10IS GEB10PS EL EL14 GLR GMF RE CSA NOM SSR BDP	One 4-lamp ballast (32W, electronic ballast only) T8 Electronic ballast, ≤10% THD, instant start Electronic ballast, ≤10% THD, programmed start Emergency battery pack (nominal 300 lumens, see Life Safety Section) Emergency battery pack (nominal 1200 lumens, see Life Safety Section) Internal fast-blow fuse <sup>3</sup> Internal slow-blow fuse <sup>3</sup> 120V residential electronic ballast <sup>4</sup> Listed and labeled to comply with Canadian Standards NOM certified Specular silver interior finish (95% reflective) Factory Installed Ballast Disconnect Plug


• • • • • • • • •	1 T5HO only available in two-lamp configuration.
Accessories: Order as separate catalog number.	2 Electronic ballast 120 through 277V only.
SQ_ Swivel-stem hanger (specify in 2" increments).	3 Must specify voltage, 120V or 277V.

1B Ceiling spacer (adjusts from 1-1/2" to 2-1/2" from ceiling). 4 Must specify voltage, 120V.

Notes

# **MOUNTING DATA**


### For unit or row installation. Surface or stem mounting. UNIT INSTALLATION — Two single-stem hangers required. ROW INSTALLATION — One hanger per fixture plus one per row required.



A = 1/4 x 1/2 (.635 x 1.27) Oval Hole B = 7/8 (2.22) Dia. K.O. C = 11/16 (1.74) Dia. K.O.

# DIMENSIONS

All dimensions are inches (centimeters) unless otherwise indicated. Specifications subject to change without notice.



# **PHOTOMETRICS**

Calculated using the zonal cavity method in accordance with IESNA LM41 procedure. Floor reflectances are 20%. Lamp configurations shown are typical. All data based on 25°C. Full photometric data on these and other configurations available upon request.

## SB 4 32

Report LTL 5659 - Lumens per lamp = 2900

#### S/MH (along) 1.2 (across) 1.3

### **Coefficient of Utilization**

Ceiling Wall	70%	80% 50%	30%	70%	70% 50%	30%	50%	50% 30%	10%	0% 0%
0	83	83	83	81	81	81	76	76	76	65
1	77	73	71	74	71	69	67	65	63	55
2	70	65	61	68	63	59	60	56	54	48
3	65	58	53	63	56	52	54	49	46	41
4	60	52	46	58	51	45	48	44	40	36
5	55	46	40	53	45	40	43	38	34	31
6	51	42	36	49	41	35	39	34	30	27
7	47	38	32	45	37	31	35	30	27	24
8	43	34	28	42	33	28	32	27	23	21
9	40	30	25	38	30	24	28	24	20	18
10	37	28	22	36	27	22	26	21	18	16

### **Zonal Lumens Summary**

Zone	Lumens	%Lamp	%Fixture
0-30	2289	19.7	27.7
0-40	3753	32.4	45.4
0-60	6182	53.3	74.7
0-90	7541	65.0	91.1
90-180	733	6.3	8.9
0-180	8275	71.3	100.0

( LITHONIA LIGHTING