

Recessed pendent sprinklers

Project information

|                                |                 |
|--------------------------------|-----------------|
| Job name:                      | Location:       |
| Engineer:                      | Date submitted: |
| Contractor:                    | Submitted by:   |
| Manufacturer's representative: | Approved by:    |

Technical data

|                         |                                     |
|-------------------------|-------------------------------------|
| Temp/pressure ratings   | 73 °F (23 °C) at 160 psi (11 bar)   |
|                         | 180 °F (82 °C) at 100 psi (6.9 bar) |
|                         | 200 °F (93 °C) at 80 psi (5.5 bar)  |
| Prop 65 label required? | Yes                                 |

Product information and application use

Recessed pendent sprinklers thread onto Uponor's fire sprinkler adapter fittings, used in fire safety applications.



| Part name                                                | Part no.  | Weight per UOM [lbs/UOM] |
|----------------------------------------------------------|-----------|--------------------------|
| LF Recessed Pendent Sprinkler, 155F, 3.0 K-factor, White | LF73000WH | 0.15                     |
| LF Recessed Pendent Sprinkler, 155F, 4.9 K-factor, White | LF74900WH | 0.15                     |
| LF Recessed Pendent Sprinkler, 175F, 4.9 K-factor, White | LF74901WH | 0.15                     |

Installation

Related applications

|     |                               |
|-----|-------------------------------|
| N/A | AquaSAFE™ Fire Safety Systems |
|-----|-------------------------------|

Footnotes

Contact information

|   |                                                                                                     |                                                                                                 |
|---|-----------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------|
| - | Uponor Inc.<br>5925 148th Street West<br>Apple Valley, MN 55124<br>T 800.321.4739<br>F 952.891.2008 | Uponor Ltd.<br>6510 Kennedy Road<br>Mississauga, ON L5T 2X4<br>T 888.594.7726<br>F 800.638.9517 |
|---|-----------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------|