
# CST135UC/CST150UC

# **USER MANUAL**



## **FEATURES**

- 1. Power Switch
- 2. Power On Indicator
- 3. LCD module display
- 4. Display/Select Button
- 5. USB Charging Ports
- 6. Battery and Surge Protected Outlets
- 7. Full-Time Surge Protection Outlets
- 8. Circuit Breaker
- 9. USB Ports to PC
- 10. Communication Protection Ports
- 11. Coax/Cable/DSS Surge Protection
- 12. Wiring Fault Indicator (red)
- 13 . Widely Spaced Outlets Designed for AC Adapters

# PRODUCT REGISTRATION

Thank you for purchasing a CyberPower product. Please take a few minutes to register your product at: <a href="mailto:cyberpowersystems.com/registration">cyberpowersystems.com/registration</a>. Registration certifies your product's warranty, confirms your ownership in the event of a product loss or theft and entitles you to free technical support. Register your product now to receive the benefits of CyberPower ownership

## **IMPORTANT SAFETY WARNINGS (SAVE THESE INSTRUCTIONS)**

When using electrical appliances, basic safety precautions should always be followed to reduce the risk of fire, electric shock, and/or injury to persons including the following. This Manual Contains Important Instructions that should be followed during installation and maintenance of the UPS and batteries

CAUTION! To prevent the risk of fire or electric shock, install in a temperature and humidity controlled indoor area free of conductive contaminants. (Please see specifications for acceptable temperature and humidity range)

CAUTION! To reduce the risk of electric shock, do not remove the cover except to service the battery. Turn off and unplug the unit before servicing the batteries. There are no user serviceable parts inside except for the battery.

CAUTION! Hazardous live parts inside can be energized by the battery even when the AC input power is disconnected. CAUTION! The UPS must be connected to an AC power outlet with fuse or circuit breaker protection. Do not plug into an outlet that is not grounded. If you need to de-energize this equipment, turn off and unplug the unit

CAUTION! To avoid electric shock, turn off the unit and unplug it from the AC power source before servicing the battery.

**CAUTION!** Not for use in a computer room as defined in the Standard for the Protection of Electronic Computer/Data Processing Equipment, ANSI/NFPA 75.

CAUTION! To reduce the risk of fire. connect only to a circuit provided with 20 amperes maximum branch circuit over current protection in accordance with the National Electric Code, ANSI/NFPA 70.

DO NOT USE FOR MEDICAL OR LIFE SUPPORT EQUIPMENT! CvberPower Systems does not sell products for life support or medical applications. DO NOT use in any circumstance that would affect the operation and safety of life support equipment, medical applications, or patient

# DO NOT USE WITH OR NEAR

AQUARIUMS! To reduce the risk of fire or electric shock, do not use with or near an aquarium. Condensation from the aguarium can cause the unit to short out.

# DO NOT USE THE UPS ON ANY

TRANSPORTATION! To reduce the risk of fire or electric shock, do not use the unit on any transportation such as airplanes or ships. The effect of shock or vibration caused during transit and the damp environment can cause the unit to short

# INSTALLING YOUR UPS SYSTEM

## UNPACKING

Inspect the UPS upon receipt. The box should contain the following: (b) User's manual (c) USB A+B type cable

(d) Function Setup Guide


\*PowerPanel\* Personal software is available on our website. Please visit cyberpowersystems.com and go to the Software Section for free download.

## OVERVIEW

The CST135UC/CST150UC provides complete power protection from utility power that is not always consistent. The CST135UC/CST150UC features 1500 Joules of surge protection. The unit provides long lasting battery backup during power outages with maintenance free batteries. The CST135UC/CST150UC ensures consistent power to your computer system and includes software that will automatically save your open files and shutdown your computer system during a utility power loss.

# AUTOMATIC VOLTAGE REGULATOR

The CST135UC/CST150UC stabilizes inconsistent utility power voltage to nominal levels that are safe for equipment. Inconsistent incoming utility power may be damaging to important data files and hardware, but with Automatic Voltage Regulation (AVR), damaging voltage levels are corrected to safe levels. AVR automatically increases low utility power to a consistent and safe 110/120 volts.



#### DETERMINE THE POWER REQUIREMENTS OF YOUR EQUIPMENT

- . Ensure that the equipment plugged into the outlet does not exceed the UPS's rated capacity (1350VA/810W for CST135UC, 1500VA/900W for CST150UC). If the rated capacity of the unit is exceeded, an overload condition may occur and cause the UPS to shut down or the circuit breaker to trip.
- 2. There are many factors that can affect the amount of power that your computer system will require. It is suggested that the load placed on the battery outlets not exceed 80% of the unit's capacity.

#### INSTALLING YOUR UPS SYSTEM - Continued

## HARDWARE INSTALLATION GUIDE

. Your new UPS may be used immediately upon receipt. However, after receiving a new UPS, to ensure the battery's maximum charge capacity, it is recommended that you charge the battery for at least 8 hours. Your UPS is equipped with an auto-charge feature. When the UPS is plugged into an AC outlet, the battery will automatically charge whether the UPS is turned on or

Note: This UPS is designed with a safety feature to keep the system from being turned on during shipment. The first time you turn the UPS on, you will need to have it connected to AC power or it will not power up. 2. With the UPS


unit turned off

and unplugged, connect your computer, monitor. and any other peripherals requiring battery backup into the battery power supplied outlets. DO NOT plug a laser printer, paper shredder, copie space heater, vacuum, sump pump or other large electrical devices into the "Battery and Surge Protected Outlets". The power demands of these devices may overload and damage the

3 . Plug the UPS into a 2 pole, 3 wire grounded receptacle (wall outlet). Make sure the wall branch outlet is protected by a fuse or circuit breaker and does not service equipment with large electrical demands (e.g. air conditioner, copier, etc...). The warranty prohibits the use of extension cords, outlet strips, and surge strips.

4 . Press the power switch to turn the unit on. The Power On indicator light will illuminate and the unit will "beep". If an overload is detected, an audible alarm will sound and the unit will emit one long beep. To correct this, turn the UPS off and unplug at least one piece of equipment from the battery power supplied outlets. Make sure the circuit breaker is depressed and then turn the UPS on.

- . To maintain optimal battery charge, leave the UPS plugged into an AC outlet at all times
- 6. To store the UPS for an extended period cover it and store with the battery fully charged. While in storage, recharge the battery every three months to ensure battery life.
- . Ensure the wall outlet and UPS are located near the equipment being attached for proper accessibility.



#### BASIC OPERATION

- 1 . Power Switch: Used as the master on/ off switch for equipment connected to the battery power supplied outlets. (Please refer to the Function Setup Guide for more information.)
- 2 . Power On Indicator: his LED is illuminated when the utility power is normal and the UPS outlets are providing power, free of surges and spikes.
- 3 . LCD module display: The LCD display shows all the UPS information using icons and messages. For more information please review the "Definitions for Illuminated LCD Indicators" section below
- 4 . Display/Select Button: The button can be used to select the LCD display contents including Input Voltage. Output Voltage, and Estimated Run Time. Short press the button to scroll down the function menu. Pressing the button for 3 seconds will keep the LCD display always on or turn the LCD display off while in AC/Utility power mode. For more information, please refer the Function Setup Guide
- 5 . USB Charging Ports: CST135UC USB Charging ports provide 5Vdc,3A Max(USB-C), and 5 Vdc, 2.4A Max(USB-A). Total Output Current:4A CST150UC USB Charging ports provide 5Vdc,2.5A Max/ 9Vdc,2A Max (USB-C), and 5 Vdc, 2.4A Max (USB-A). Total Output Current:30W
- 6 . Battery and Surge Protected Outlets: The UPS has five battery powered/surge suppression outlets for connected equipment to ensure temporary uninterrupted operation of your equipment during a power failure. (DO NOT plug a laser printer, paper shredder, copier, space heater, vacuum, sump pump or other large electrical devices into the "Battery and Surge Protected Outlets". The power demands of these devices may overload and damage the unit.)

- 7 . Full-Time Surge Protection Outlets: The UPS has five surge suppression outlets.
- 8 . Circuit Breaker: Located on the back of the UPS, the circuit breaker serves to provide overload and fault protection.
- 9 . USB Ports to PC: Use the type B to type A USB cable to connect the product to a computer.

#### 10 .Communication Protection Ports: Communication protection ports, bi-directional, will protect a 10/100/1000 Ethernet connection

(RJ45).

- 11 . Coax/Cable/DSS Surge Protection: The Coax/Cable/DSS protection ports will protect any cable modem, CATV converter, or DSS receiver.
- 12. Wiring Fault Indicator (red): This LED indicator will illuminate to warn the user that a wiring problem exists, such as bad ground, missing ground or reversed wiring. If this is illuminated. disconnect all electrical equipment from the outlet and have an electrician verify the outlet is properly wired. The UPS will not provide surge protection without being plugged into a grounded and properly wired wall outlet.
- 13. Widely Spaced Outlets Designed for AC Adapters: The unit has two outlets spaced to allow AC power adapter blocks to be plugged into the UPS without blocking adjacent outlets

# REPLACING THE BATTERY

Replacement of batteries located in an OPERATOR ACCESS AREA.

- 1 . When replacing batteries, replace with the same number of the following battery: CyberPower / RB1270X2C for the CST135UC and CyberPower / RB1290X2 for the
- $2\,$  . CAUTION! Risk of Energy Hazard, 24 V, maximum 9 Ampere-hour battery. Before replacing batteries, remove conductive jewelry such as chains, wrist watches, and rings. High energy conducted through these materials could cause severe burns.
- 3 . CAUTION! Do not dispose of batteries in a fire. The batteries may explode 4 . CAUTION! Do not open or mutilate batteries. Released material is harmful to the skin
- and eyes. It may be toxic.  ${\bf 5}\,$  . CAUTION: A battery can present a risk of electrical shock and high short circuit current. The following precautions should be observed when working on batteries. 1) Remove watches rings, or other metal objects.

CAUTION - RISK OF EXPLOSION IF BATTERY IS REPLACED BY AN INCORRECT TYPE. DISPOSE OF USED BATTERIES ACCORDING TO LOCAL REGULATIONS.


# BATTERY REPLACEMENT PROCEDURE:


- . Switch off and unplug all the connected equipment.
- 2 . Switch off the UPS and disconnect it from the wall outlet. 3 . Place the product on its side, on a solid and stable surface
- 4 . Loosen the battery compartment cover screws.
- 5. Press on the locking latch and slide the battery compartment cover.
- 6 . Disconnect the battery wires from the right side of the battery and then take it out of the battery compartment.
- 7 . Disconnect the battery wires from the remaining battery.
- $\boldsymbol{8}\,$  . Slide the remaining battery from left to right and remove it from the compartment.
- 9 . Install the "left side" replacement battery by connecting the yellow wire (+) to the red connector from the battery and the black wire (-) to the black connector from the battery. Place the battery into the left side of the compartment. 10 . Install the "right side" replacement battery by connecting the red wire (+) to the
- red connector from the battery and vellow wire (-) to the black connector from the battery. Place the battery into the right side of the compartment. Note: Only new batteries should be used for replacement and both batteries should be replaced a the same time to ensure maximum life span.
- 11 . Close the battery compartment cover and secure it with the screws.
- Recharge the UPS for 8-16 hours to fully charge the battery




2) Use tools with insulated handles














Yellow Wire to (-) Black Connector

REMINDER: Batteries are considered HAZARDOUS WASTE and must be disposed of properly. Most retailers that sell lead-acid batteries collect used batteries for recycling, as required by local regulations

# **DEFINITIONS FOR ILLUMINATED LCD INDICATORS**



The LCD display indicates a variety of UPS operational conditions. All descriptions apply when the UPS is plugged into an AC outlet and turned on or when the UPS is on battery.

1 . INPUT voltage meter: This meter measures the AC voltage that the UPS system is receiving from the utility wall outlet. The UPS is designed, through the use of automatic voltage regulation, to continuously correct output voltage to connected equipment to a safe 110/120 voltage output range. In the event of a complete power loss, severe brownout, or over-voltage, the UPS relies on its internal battery to supply consistent 110/120 output voltage. The INPUT voltage meter can be used as a diagnostic tool to identify poor-quality input power.

- 2 . OUTPUT voltage meter: This meter measures, in real time, the AC voltage that the UPS system is providing to the connected devices, such as normal line mode, AVR mode, and battery backup mode. (Note: The OUTPUT voltage meter shows the status of the battery backup outlets.)
- ESTIMATED RUN TIME: This displays the run time estimate of the UPS with current battery capacity and load.
- 4 . NORMAL icon: This icon appears when the UPS is working under normal conditions.
- 5 . BATTERY icon: During a severe brownout or blackout, this icon appears and an alarm sounds (two short beeps followed by a pause) to indicate the UPS is operating from its internal batteries. During a prolonged brownout or blackout, the alarm will sound continuously to indicate the UPS's batteries are nearly out of power. You should save files and turn off your equipment immediately or allow the software to shut the system down.
- 6 . AVR (Automatic Voltage Regulation) icon: This icon appears whenever your UPS is automatically correcting low AC line voltage without using battery power. This is a normal, automatic operation of your UPS, and no action is required on your part.
- 7 . SILENT MODE icon: This icon appears whenever the UPS is in silent mode. The buzzer does not beep during silent mode until the battery reaches low capacity.
- 8 . OVER LOAD icon: This icon appears and an alarm sounds to indicate the battery-supplied outlets are overloaded. To clear the overload, unplug some of your equipment from the battery-supplied outlets until the icon turns off and the alarm charge.
- 9 . FAULT: This icon appears if there is a problem with the UPS. Press the POWER button to turn the UPS off.
  - **E01 : Charger Fault-Overcharge** (Contact CyberPower Systems for support.)
- E02: Charger Fault-No Charge (Contact CyberPower Systems for support.)
  E11: Battery Overvoltage (Contact CyberPower Systems for support.)
- E21: Output Short (Check the status of equipment connected to the UPS and then turn on the UPS again.)
- **E22: Overload** (Unplug at least one piece of equipment from battery outlets and turn the UPS on again.)
- 10. BATT. CAPACITY meter: This meter displays the approximate charge level (in 20% increments) of the UPS's internal battery. During a blackout or severe brownout, the UPS switches to battery power, the BATTERY icon appears, and the charge level decreases.
- 11. LOAD CAPACITY meter: This meter displays the approximate output load level (in 20% increments) of the UPS battery outlets.

For more information about functions setup, please refer to the Function Setup Guide.


#### **TROUBLESHOOTING**

Problem	Possible Cause	Solution
Circuit breaker button is projecting from the back of the unit.	Circuit breaker has tripped due to an overload.	Turn the UPS off and unplug at least one piece of equipment. Wait 10 seconds, reset the circuit breaker by depressing the button, and then turn the UPS on.
The UPS does not perform expected runtime.	Battery not fully charged.	Recharge the battery by leaving the UPS plugged in.
	Battery is worn out.	Please contact CyberPower Systems about replacement batteries.
The UPS will not turn on.	The on/off switch is designed to prevent damage from rapidly turning it off and on.	Turn the UPS off. Wait 10 seconds and then turn the UPS on.
	The unit is not connected to an AC outlet.	The unit must be connected to a 120V 60Hz outlet.
	The battery is worn out.	Please contact CyberPower Systems.
	Mechanical problem.	Please contact CyberPower Systems.
PowerPanel* Personal is inactive (all icons are gray).	The USB cable is not connected.	Connect the USB cable to the UPS unit and an open USB port on the back of the computer. You must use the cable that came with the unit.
	The USB cable is connected to the wrong port.	Check the back of the computer for an additional USB port. Move the cable to this port.
	The unit is not providing battery power.	Shutdown your computer and turn the UPS off. Wait 10 seconds and turn the UPS back on. This should reset the unit.
The USB power ports are not providing power to the connected devices.	The USB power port has Over Current Protection design. When the total current of connected devices is over specification, the USB power ports will stop providing power to the connected devices.	Turn the UPS off and unplug at least one piece of device connected to the USB power port and then turn the UPS on.

### TECHNICAL SPECIFICATIONS

Model	CST135UC	CST150UC
Capacity	1350VA / 810W	1500VA/900W
Nominal Input Voltage	120V	
Input Frequency	60 Hz ± 3 Hz	
On-Battery Output Voltage	120Vac ± 5%	
Max. Load for UPS Outlets (5 Outlets)	1350VA / 810W	1500VA/900W
Max. Load for Full-Time Surge Protection outlets (10 Outlets)	12 Amp	
On-Battery Output Wave Form	Simulated Sine Wave	
Operating Temperature	+ 32°F to 104° F / 0° C to 40° C	
Operating Relative Humidity	0 to 95% non-condensing	
Size (W x H x D)	3.9" x 9.8" x 13.7" (99 x 249 x 348 mm)	
Net Weight	23.59lbs / 10.7kg	25lbs/11.3kg
Battery Type	CyberPower / RB1270X2C	CyberPower / RB1290X2
Typical Battery Recharge Time	8 hours to 90% capacity from total discharge	
Typical Battery Life	3 to 6 years, depending on number of discharge/recharge cycles	
Recommended Battery	Sealed Maintenance Free Lead Acid Battery	
Safety Approvals	UL1778(UPS), CSA C22.2 No. 107, FCC/DoC Class B	

#### SYSTEM FUNCTIONAL BLOCK DIAGRAM



# CYBERPOWER GREENPOWER UPS $^{\scriptscriptstyle{\mathsf{TM}}}$ TECHNOLOGY

## **Advanced Energy-Saving Patented Bypass Technology**

CyberPower's patented GreenPower UPS™ with Bypass Technology reduces UPS energy costs by up to 75% compared to conventional UPS models. Even when utility power is normal, conventional UPS models constantly pass power through a transformer. By contrast, under normal conditions the advanced circuitry of a GreenPower UPS™ bypasses the transformer. As a result, the power efficiency is significantly increased while decreasing waste heat, using less energy, and reducing energy costs.

When an abnormal power condition occurs, the GreenPower UPS™ automatically runs power through its transformer to regulate voltage and provide "safe" power. Since utility power is normal over 88% of the time, the GreenPower UPS™ operates primarily in its efficient bypass mode.

The GreenPower UPS™ is also manufactured in accordance with the Restriction on Hazardous Substances (RoHS) directive making it one of the most environmentally-friendly on the market today.

# FCC COMPLIANCE STATEMENT

This device complies with part 15 of the FCC rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Note: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user

is encouraged to try to correct the interference by one or more of the following measures:

# FCC COMPLIANCE STATEMENT - Continued

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment to an outlet on a circuit different from that to which the receiver is connected.

**Warning:** Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

## Canadian Compliance Statement

CAN ICES-3 (B)/NMB-3(B)

# LIMITED WARRANTY AND CONNECTED EQUIPMENT GUARANTEE

Please visit www.CyberPowerSystems.com for a copy of the Limited Warranty and Connected Equipment Guarantee.

# Where Can I Get More Information?

The application of the United Nations Convention of Contracts for the International Sale of Goods is expressly excluded. CyberPower is the warrantor under this Limited Warranty.

For further information please feel free to contact CyberPower at:

Cyber Power Systems (USA), Inc.

4241 12th Ave E., STE 400, Shakopee, MN 55379;

Call us at (877) 297-6937;

or submit a web ticket online at cyberpowersystems.com/support.

**WARNING:** This product can expose you to chemicals including bisphenol A (BPA) and styrene, which is known to the State of California to cause reproductive harm and cancer. For more information, go to www.P65Warnings.ca.gov.

## CvberPowerSvstems.com

© 2021 Cyber Power Systems (USA), Inc. PowerPanel\* Personal is a trademark of Cyber Power Systems (USA) Inc.

All rights reserved. All other trademarks are the property of their respective owners.