



Installation/Care/Use Manual

Heavy Duty 14 Gauge Barrier Free Slimline[®] Freeze Resistant Fountains



EHWM14FP



EHWM17FP

Installer

To assure you install this model easily and correctly, PLEASE READ THESE SIMPLE INSTRUCTIONS BEFORE STARTING THE INSTALLATION. CHECK YOUR INSTALLATION FOR COMPLIANCE WITH PLUMBING, ELECTRICAL AND OTHER APPLICABLE CODES. After installation, leave these instructions inside the fountain for future reference. This Freeze Resistant Fountain is shipped in two separate cartons. The second carton(s) contains the Freeze Resistant Package(s) **LKFRB1** that are installed on an interior heated wall. The interior space must maintain a minimum temperature of 50° F (10° C). Refer to the Freeze Resistant Package for the rough-in dimensions for installation.

IMPORTANT


ALL SERVICE TO BE PERFORMED BY AN AUTHORIZED SERVICE PERSON

IMPORTANT! INSTALLER PLEASE NOTE.

THE GROUNDING OF ELECTRICAL EQUIPMENT SUCH AS TELEPHONE, COMPUTERS, ETC. TO WATER LINES IS A COMMON PROCEDURE. THIS GROUNDING MAY BE IN THE BUILDING OR MAY OCCUR AWAY FROM THE BUILDING. THIS GROUNDING CAN CAUSE ELECTRICAL FEEDBACK INTO A FOUNTAIN, CREATING AN ELECTROLYSIS WHICH CAUSES A METALLIC TASTE OR AN INCREASE IN THE METAL CONTENT OF THE WATER. THIS CONDITION IS AVOIDABLE BY USING THE PROPER MATERIALS AS INDICATED. ANY DRAIN FITTINGS PROVIDED BY THE INSTALLER SHOULD BE MADE OF PLASTIC TO ELECTRICALLY ISOLATE THE FOUNTAIN FROM THE BUILDING PLUMBING SYSTEM.

EHWM14FP MOUNTING BOLT AND ACCESS HOLE LAYOUT

FIG. 1



- LEGEND**
- A = 1-3/4" DIA. (44mm) HOLE FOR WASTE LINE
 - B = 7/8" DIA. (22mm) HOLE FOR WATER SUPPLY TUBE
 - C = 7/8" DIA. (22mm) HOLE FOR OPERATING CABLE
 - D = 1/4" DIA. (6mm) HOLES FOR MOUNTING PLATE TO WALL
 - E = 3/8" DIA. (10mm) HOLES FOR MOUNTING PLATE TO WALL

Technical drawing of the 1000 Series Locking Mailbox, showing front and side views with dimensions in inches and millimeters.

Front View Dimensions:

- Overall Width: 20 3/8" (516mm)
- Overall Height: 24 1/2" (622mm)
- Top Flange Width: 19 3/4" (502mm)
- Top Flange Height: 3 13/16" (97mm)
- Mailbox Body Width: 12 1/8" (309mm)
- Mailbox Body Height: 4 3/8" (111mm)
- Bottom Flange Width: 20 3/8" (516mm)
- Bottom Flange Height: 24 1/2" (622mm)

Side View Dimensions:

- Overall Depth: 12 1/8" (309mm)
- Mailbox Body Depth: 4 3/8" (111mm)
- Bottom Flange Depth: 20 3/8" (516mm)
- Bottom Flange Height: 24 1/2" (622mm)

Additional Dimensions:

- Top Flange Thickness: 5/8" (16mm)
- Mailbox Body Thickness: 12" (305mm) MAX. WALL THICKNESS
- Bottom Flange Thickness: 2 5/8" (66mm)
- Bottom Flange Height: 3 5/8" (91mm)
- Mailbox Body Height: 16 7/8" (429mm)
- Mailbox Body Width: 13 3/8" (340mm)
- Mailbox Body Depth: 12 3/8" (315mm)
- Mailbox Body Thickness: 28" (711mm)


Notes:

- 33" (838mm) Office Height
- Enriched Floor
- *27" (686mm)

- * Adult ADA Requirement
 **24" for Child ADA, adjust other measurements accordingly.

EHWM17FP **MOUNTING BOLT AND ACCESS HOLE LAYOUT**


FIG. 3



- LEGEND**
 A = 1-3/4" DIA. (44mm) HOLE FOR WASTE LINE
 B = 7/8" DIA. (22mm) HOLE FOR WATER
 SUPPLY TUBE
 C = 7/8" DIA. (22mm) HOLE FOR OPERATING
 CABLE
 D = 1/4" DIA. (6mm) HOLES FOR MOUNTING
 PLATE TO WALL
 E = 3/8" DIA. (10mm) HOLES FOR MOUNTING
 PLATE TO WALL

EHWM17FP ROUGH-IN DRAWINGS

FIG. 4



1. Wall should already be framed for the fountain using dimensions shown in Fig. 3. Shown dimensions pertain to installation location.
These dimensions are required for compliance with ANSI Standard A117.1. and ADA (Framing shown for reference only).

2. Remove bottom cover from fountain and save the screws.

3. Install the fountain using bolts and washers (not provided). Tighten securely.

4. Attach drain tube to fountain and cut to required length using the freeze resistant box as a guide.

5. Install freeze-resistant box - see box instructions.

6. Replace bottom cover.

*** Adult ADA Requirement**
****24" for Child ADA, adjust other**
measurements accordingly.





FIG. 5

CABLE SHEATH ADJUSTMENT

To Increase Free Play



To Reduce Free Play




FIG. 6




FIG. 7




FIG. 8

The freeze resistant package must be mounted on an interior wall in a heated area. The room temperature of the interior heated area must be 50° F (10° C) or higher. The freeze resistant package may be surface or recessed mounted. If recess mounted the surface of the cover must be flush with the interior wall surface. The package is furnished with screws for mounting the cover to the box. If the box is recess mounted, do not fasten the top and bottom of the cover to the box. Use the holes on the front only.

1. Assemble the operating cable to the fountain bracket. (Fountain should be mounted to exterior wall) Create a loop in the cable and thread the free end of the cable through the wall into the freeze resistant box. The adjustment nuts should be in the middle of threaded area on the operating cable. See Figure 8
2. Connect free end of operating cable to the valve-operating bracket. The end of the cables must be recessed into the indents on the pivot brackets.
3. Remove cable free play by adjusting the jam nuts on the ends of the operating cable. See Figure 6
4. Connect water line from fountain bubbler into freeze resistant box. The connection to the box uses a quick connect water fitting. Position the water line, in the fountain, to drain back into interior mounted box. Any water left standing, in the exterior line, can freeze.

To insert tubing, push tube straight into fitting until it reaches a positive stop. To remove tubing from the fittings, relieve water pressure, push in on dark gray collar while pulling out on the tubing. See Figure 10

5. Connect drain and water supply lines to the freeze resistant fountain. Refer to Figure 1 for component positions. Inline strainer must be used on the inlet water line.

Start-up

1. Turn on building water supply and check all connections for leaks. Repair as required.
2. Stream height is factory set at 35 PSI. If stream height needs to be changed adjust the regulator in the freeze resistant package. Clockwise adjustment raises stream height, counter clockwise adjustment will lower stream.
3. Adjust operating cable as required. Cable system should have a minimal amount of free play to allow for proper valve operation. If the system is too tight the valve will stay in the on position creating constant water flow. Too much free play will result in non-operation of the valve with the push-buttons.
4. Note: Water from the drain back tube in the freeze resistant package, will continue to run while the valve is actuated.
5. After cable system is adjusted properly stuff flexible insulation into any openings between the outside wall and the interior box.
6. Recheck all connections. If all connections are leak free replace cover(s) on the freeze resistant box(es) and fountain(s).





FIG. 9

OPERATION OF QUICK CONNECT FITTINGS



PUSHING TUBE IN BEFORE PULLING IT OUT HELPS TO RELEASE TUBE

FIG. 10

PARTS LIST

ITEM NO.	PART NO.	DESCRIPTION
1	100322740560	GASKET
2	15009C	NIPPLE ASSY
3	27945C	BRACKET-BASIN
4	27946C	BRACKET-BASIN PIVOT
5	28630C	BOTTOM COVER PLATE
6	28798C	MTG. PLATE ASSY. (EHWM14FP)
	28801C	MTG. PLATE ASSY. (EHWM17FP)
7	28800C	BACK PANEL (EHWM14FP)
	28802C	BACK PANEL (EHWM17FP)
8	28824C	BRACKET-REGULATOR MOUNTING
9	40045C	HEX NUT 1-5/16
10	40206000	RETAINER
11	98118C	BUBBLER ASSEMBLY
12	45662C	PUSH BUTTON
13	45727C	SLEEVE-PUSH BUTTON GUIDE
14	45678C	DRAIN PLUG 1-1/2"
15	45769C	DRAIN/TAILOPIPE ASSEMBLY
16	50198C	SNAP BUSHING
17	51667C	BUMPER-REG. VALVE ASSY
18	55001162	FOUNTAIN ARM
19	55919C	PUSH BUTTON (EXTENSION)
20	56092C	POLY TUBING (CUT TO LENGTH)
21	56163C	DRAIN GASKET
22	56280C	EDGE TRIM
23	70425C	PIVOT ROD
24	75570C	SCREW-#10 x .50 PINNED TORX
25	75672C	CAP SCREW-#6-32
NS	111577243890	SCREW-MACH. 5/16-18 x 3/4
NS	66744C	TAILPIECE ASSEMBLY 1-1/4 x 12"
NS	75520C	PINNED TORX BIT T-25
NS	75541C	FLAT WASHER




FIG. 9




FIG. 11

FOR PARTS, CONTACT YOUR LOCAL DISTRIBUTOR OR CALL 1.800.323.0620
 ELKAY MANUFACTURING COMPANY • 2222 CAMDEN COURT • OAK BROOK, IL 60523 • 630.574.8484

PRINTED IN U.S.A.