

**GE Current, a Daintree company**

1975 Noble Road  
E. Cleveland, OH 44112  
USA

## **Certificate of Analysis**

### **Reporting Analytical Lab**

#### **Multiple Laboratories**

DESCRIPTION: **T12 Ecolux High Output, Watt-Miser, Fluorescent Lamps - 8'**  
MODEL: **F96T12CW/HO/WM/ECO**

#### **Test**

**Toxicity Characteristic Leaching Procedure (TCLP)  
for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste  
Physical/Chemical Methods, SW-846**

**Tested in accordance with ANSI Standard, ANSI/NEMA C78. LL1256-2003,  
"Procedures for Linear Fluorescent Lamp Sample Preparation and the TCLP."**

#### **TCLP Maximum Allowable Concentration for Mercury**

- **0.200 mg/Liter (USA)**

NUMBER OF LAMPS: **11**

#### **Result Summary**

Average Result: **0.130 mg/L**

Standard Deviation: **0.030**

90% Confidence Limit: **0.140 mg/L**

TCLP RESULT: **PASSED USA**