

**GE Current, a Daintree company**

1975 Noble Road  
E. Cleveland, OH 44112  
USA

## **Certificate of Analysis**

### **Reporting Analytical Lab**

**Alpha Analytical Labs**  
Westborough, MA 01581-1019

**DESCRIPTION: T8 Ecolux CovRGuard Fluorescent Lamps - 4'**  
**MODEL: F32T8/SP30/ECO/CVG**

### **Test**

**Toxicity Characteristic Leaching Procedure (TCLP)**  
**for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste**  
**Physical/Chemical Methods, SW-846**

**Tested in accordance with ANSI Standard, ANSI/NEMA C78. LL1256-2003,**  
**“Procedures for Linear Fluorescent Lamp Sample Preparation and the TCLP.”**

### **TCLP Maximum Allowable Concentration for Mercury**

- **0.200 mg/Liter (USA)**
- **0.100 mg/Liter (Canada)**

**NUMBER OF LAMPS: 10**

### **Result Summary**

**Average Result: 0.048 mg/L**

**Standard Deviation: 0.004**

**90% Confidence Limit: 0.050 mg/L**

**TCLP RESULT: PASSED USA & CANADA**