

GE Current, a Daintree company

1975 Noble Road
E. Cleveland, OH 44112
USA

Certificate of Analysis

Reporting Analytical Lab

Alpha Analytical Labs
Westborough, MA 01581-1019

DATE: **May-00**

DESCRIPTION: **70W Ecolux High Pressure Sodium Lamps**

MODEL: **LU70/ECO**

Test

**Toxicity Characteristic Leaching Procedure (TCLP)
for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste
Physical/Chemical Methods, SW-846**

**Tested in accordance with NEMA Standard, NEMA LL 3,
"Procedures for High-Intensity Discharge Lamp Sample Preparation and the TCLP."**

TCLP Maximum Allowable Concentration for Mercury

- **0.200 mg/Liter (USA)**

NUMBER OF LAMPS: **3**

Result Summary

Average Result: **0.084 mg/Liter**

Standard Deviation: **0.022**

90% Confidence Limit: **0.105 mg/Liter**

TCLP RESULT: **PASSED – USA**