

**GE Current, a Daintree company**

1975 Noble Road  
E. Cleveland, OH 44112  
USA

## Certificate of Analysis

### Reporting Analytical Lab

**Alpha Analytical Labs**  
Westborough, MA 01581-1019

DATE: **October-04**  
DESCRIPTION: **T5 Ecolux Fluorescent Lamps - 4'**  
MODEL: **F28W/T5/ECO and F54W/T5/ECO**

### Test

**Toxicity Characteristic Leaching Procedure (TCLP)**  
**for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste**  
**Physical/Chemical Methods, SW-846**

**Tested in accordance with NEMA Standard, NEMA LL 1,**  
**“Procedures for Linear Fluorescent Lamp Sample Preparation and the TCLP.”**

### TCLP Maximum Allowable Concentration for Mercury

- **0.200 mg/Liter (USA)**
- **0.100 mg/Liter (Canada)**

NUMBER OF LAMPS: **20**

### Result Summary

Average Result: **0.012 mg/Liter**

Standard Deviation: **0.004**

90% Confidence Limit: **0.014 mg/Liter**

TCLP RESULT: **PASSED USA & CANADA**