



1. EU-TYPE EXAMINATION CERTIFICATE

2. Equipment or Protective systems intended for use in Potentially Explosive Atmospheres - Directive 2014/34/EU

3. EU-Type Examination Certificate No: FM21ATEX0083X

4. Equipment or protective system:
(Type Reference and Name) PrimaX IR Gas Monitor
PrimaX IR+ Gas Detector Controller

5. Name of Applicant: MSA Innovation LLC dba MSA - The Safety Company

6. Address of Applicant 1000 Cranberry Woods Drive, Cranberry Township, Pennsylvania 16066, United States of America

7. This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and documents therein referred to.

8. FM Approvals Europe Ltd, notified body number 2809 in accordance with Article 17 of Directive 2014/34/EU of 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report number:

PR461386 dated 28th February 2022

9. Compliance with the Essential Health and Safety Requirements, with the exception of those identified in item 15 of the schedule to this certificate, has been assessed by compliance with the following documents:

EN 50271:2018, EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-29-1:2016+A1:2022+A11:2022,
EN 60079-31:2014, EN 60529:1991+A1:2000+A2:2013

10. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

11. This EU-Type Examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

Certificate issued by:

 FM Approvals

4 February 2025

Certification Manager, FM Approvals Europe Ltd.

Date

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com



SCHEDULE

EU-Type Examination Certificate No. FM21ATEX0083X

FM Approvals

12. The marking of the equipment or protective system shall include:



Refer to Annex

13. Description of Equipment or Protective System:

Refer to Annex

14. Specific Conditions of Use:

Refer to Annex

15. Essential Health and Safety Requirements:

The relevant EHSRs that have not been addressed by the standards listed in this certificate have been identified and assessed in the confidential report identified in item 8.

16. Test and Assessment Procedure and Conditions:

This EU-Type Examination Certificate is the result of testing of a sample of the product submitted, in accordance with the provisions of the relevant specific standard(s), and assessment of supporting documentation. It does not imply an assessment of the whole production.

Whilst this certificate may be used in support of a manufacturer's claim for CE Marking, FM Approvals Europe Ltd accepts no responsibility for the compliance of the equipment against all applicable Directives in all applications.

This Certificate has been issued in accordance with FM Approvals Europe Ltd's ATEX Certification Scheme.

17. Schedule Drawings

A list of the significant parts of the technical documentation is annexed to this certificate and a copy has been kept by the Notified Body. The documents are maintained under file number 3036837.

18. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
7 March 2022	Original Issue.
22 May 2023	<u>Supplement 1:</u> Report Reference: PR459559 dated 17 th May 2023. Description of the Changes: 1. Addition of PrimaX IR+ Gas Detector Controller and identification that evaluated in accordance with EN IEC 60079-0, EN 60079-1 and EN 60079-31 <u>only</u> . 1. Addition of firmware version in description of, and addition of EN 50271 as a relevant standard for, the PrimaX IR Gas Monitor Combustible Gas Detector. 2. Documentation updates not affecting the equipment safety.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmaprovals.com www.fmaprovals.com

SCHEDULE

EU-Type Examination Certificate No. FM21ATEX0083X



Date	Description
28 November 2024	<u>Supplement 2:</u> Report Reference: PR467913 dated 25th November 2024. Description of the Change(s): 1. For PrimaX IR+ Gas Detection Controller 1. Qualification of PrimaX IR+ for Performance certification EN 60079-29-1 2. Removal of condition of use "<i>[t]hePrimaX IR+ has not been evaluated to the performance requirements of IEC 60079-29-1 and shall not be used to execute safety critical functions.</i>" for PrimaX IR+ 3. Change in ambient temperature from -50°C to +80°C to -40°C to +75°C 2. For PrimaX IR Gas Monitor and PrimaX IR+ Gas Detection Controller 1. Addition of IP66 for PrimaX IR and PrimaX IR+ 2. Addition of HART modules 10246266 and 10246267 as optional accessories 3. Markings, description, and model codes moved to the annex
4 February 2025	<u>Supplement 3:</u> Report Reference: RR244535 dated 3 February 2025.. Description of the Change(s): 1. For PrimaX IR+ Gas Detection Controller: supply parameter updated from "18-30 Vdc" to "20-30 Vdc"

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com

ANNEX

A-PRIMAXIR

Markings:



II 2 G Ex db IIC T4 Gb Ta = -50°C to +80°C
II 2 D Ex tb IIIC T130°C Db Ta = -50°C to +80°C
EN 60079-29-1

Description of Equipment:

The infrared gas monitor type PrimaX IR is a stationary gas detector for the measurement of hydrocarbon gases in ambient air under atmospheric conditions. The gas monitor contains an infrared sensor for gas measurement and electronic boards; it uses a cartridge type heater located near the window and mirror. The gas monitor is designed in type of protection flameproof enclosure "db" and equipment dust ignition protection by enclosure "tb". The connection of the gas monitor to other flameproof enclosures could be done via a M25 or a 3/4 NPT thread. The equipment has an ingress protection rating of IP66/67.

Model Code Options:

A-PRIMAXIR-A-B-C. Gas Monitor

A = Target Gas: 11, 12, 13, 14, 15, 16, 17, 19, 20, 27, 30, 31, 32, 33, 34, 37, 39, 41, 42, 43, 62 or 63.

B = Approval Agency: A.

C = Thread Type: M or N.

Specifications - The manufacturer's specifications are as follows:

Gases:	Methane, Propane, Ethylene, Propylene oxide, Acetone, Cyclopentane, Ethyl acetate, i-butane, propylene, Ethane, n-butane, n-pentane, toluene, n-Hexane
Ranges:	Methane, Propane, Ethylene, Propylene oxide, Acetone, Cyclopentane, Ethyl acetate: 0-100% LEL i-butane: 0-70% LEL; propylene, Ethane: 0-50% LEL; n-butane, n-pentane: toluene 0-30% LEL; n-Hexane 0-10% LEL
Operating Temperature:	-50°C to +80°C
Storage Temperature:	-50°C to +80°C
Relative Humidity:	15 to 95% RH
Supply Parameters:	18-32 Vdc, 24 Vdc (Nominal), 6 watts maximum
Measurement Signal:	4-20mA
Calibration:	Calibration Cap or HART
Firmware:	3.6
Use of the following	

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT
CHANGE**

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com

SCHEDULE

EU-Type Examination Certificate No. FM21ATEX0083X

outputs for Safety Relevant Purposes:	4-20 mA output for measured values
---------------------------------------	------------------------------------

Accessories - The following accessories may be used with the PrimaX IR Gas Detector:

Calibration Cap	p/n 10111874 (LCIE 10 ATEX 3090 X)
HART Calibration cover	p/n 10122228
Flow cap	p/n 10113100
Environmental Guard	p/n 10113663
Insect screen	p/n 10116419
Aluminum junction box kit	p/n 10117607 (NPT) and 10117606 (M25) (BVS 10 ATEX E 157 X)
Stainless steel 316 junction box kit	p/n 10117608 (NPT) and 10117609 (M25) (FM06ATEX0029U)
HART Modules	p/n 10246266 (3/4" NPT) and 1024267 (M25) (FM23ATEX0040X)
PrimaX IR link	version 1.06

Specific Conditions of Use:

1. The gas monitor PrimaX IR is equipped with a tapered NPT thread or a metric thread for mounting to a connection enclosure of protection type increased safety "e" or protection type flameproof enclosure "d".
2. When mounting the gas monitor to an enclosure of protection type flameproof enclosure "d", the reference pressure of the separate enclosure for the connection must not exceed 10.5 bar. The test of the mechanical strength of the separate enclosure for the connection and the test of the connecting thread with respect to explosion hazards must be ensured within the framework of the type test of the electrical apparatus, which is attached to the gas monitor PrimaX IR. The threaded hole to which the gas monitor is attached must meet the requirements of section 5.3 (Table 4/5) of IEC 60079-1.
3. Due to the limitations on the potting used for the wire bushing on the PrimaX IR, the service temperature within the separate enclosure (the enclosure the PrimaX IR is mounted to) must not exceed 120°C.
4. When mounting the gas monitor to enclosures in type of protection increased safety "e", the mechanical resistance and the IP protection (IP6X) of the mounted enclosure has to be ensured by the type test of the electrical apparatus being mounted to the gas monitor. After mounting of the gas monitor onto an enclosure in type of protection increased safety "e", the clearances and creepage distances must meet the requirements of Table 2 of IEC 60079-7. The non-shielded cables of the gas monitor must be routed and connected so as to be mechanically protected and corresponding to the temperature resistance of the cables as per 4.6.2, 4.8.2 and 4.9 of IEC 60079-7.
5. For dust applications, any intensive electrostatic charging processes to the instrument label has to be prevented.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin, Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com

SCHEDULE

EU-Type Examination Certificate No. FM21ATEX0083X

FM Approvals

6. The 3/4" NPT fixture has to be sealed with 2 layer PTFE sealing tape or according to the instructions of the manufacturer of the enclosure with NPT thread; when removed, new PTFE sealing has to be used after reinstalling.
7. The gas monitor PrimaX IR must be screwed into the housing wall such that it is secured against self-loosening. The specified minimum thread depth of the add-on housing has to be observed.
8. The gas monitor PrimaX IR must be included into the earthing and equipotential bonding of the complete system, including the enclosure it is connected to.
9. The screw heads are filled with potting to prevent self-loosening and unauthorized entry. The user may not open the enclosure. Opening of the device will invalidate the type approval.

PrimaX IR+

Markings:



II 2 G Ex db IIC T4 Gb Ta = -40°C to +75°C
II 2 D Ex tb IIIC T130°C Db Ta = -40°C to +75°C
EN 60079-29-1

Description of Equipment:

The gas detector controller type PrimaX IR+ Gas Detector Controller is a stationary gas detector controller for the measurement of hydrocarbon gases in ambient air under atmospheric conditions. The gas detector controller contains electronic boards used to display gas concentrations from a 4-20mA gas detector. The gas detector controller is designed in type of protection flameproof enclosure "db" and equipment dust ignition protection by enclosure "tb". The connection of the gas detector controller to other flameproof enclosures or detectors could be done via a M25 or a 3/4 NPT thread. The equipment has an ingress protection rating of IP66/67.

Model Code Options:

PrimaX IR+ Gas Detector Controller

Specifications - The manufacturer's specifications are as follows:

Operating Temperature:	-40°C to +75°C
Storage Temperature:	-40°C to +75°C
Relative Humidity:	15 to 95% RH
Supply Parameters:	20-30 Vdc, 24 Vdc (Nominal), 6 watts maximum
Optional Relay Contacts:	30VDC 2 AMPS MAX
Measurement Signal:	4-20mA
Firmware:	0.03

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin, Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com

SCHEDULE

EU-Type Examination Certificate No. FM21ATEX0083X



Approved Sensor - The following sensor has been performance tested for use with the *PrimaX IR* Gas Detector Controller:

Product/Listing Title	Company	Certificate Number
A-PRIMAXIR-A-B-C Gas Monitor	MSA Innovation LLC dba MSA - The Safety Company	FM21ATEX0083X

Specific Conditions of Use:

1. The flameproof joints of the equipment are not intended to be repaired. For maintenance or repair, contact the manufacturer.
2. The $\frac{3}{4}$ " NPT fixture has to be sealed with 2 layer PTFE sealing tape or according to the instructions of the manufacturer of the enclosure with NPT thread; when removed, new PTFE sealing has to be used after reinstalling.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT
CHANGE**

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com