

The manufacturer or his authorized representative established in the community:

General Monitors Inc.

16782 Von Karman Ave. Unit 14, Irvine, CA. 92606, United States

declare under its sole responsibility that the product(s)

IR5500 Open Path Combustible Gas Detector

is in conformity with the provisions of the following relevant directives, regulations & harmonized standards

Directive or Regulation

Harmonized standards (Prefix Number: Edition or Date)

ATEX: 2014/34/EU

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-29-4:2010

EN 60079-31:2014

EMC: 2014/30/EU

EN 50270:2015/AC2016

EN 61000-6-4:2019

Additional Information

ATEX: 2014/34/EU

Based on the EC-Type Examination Certificate **FM10ATEX0031X** issued by **FM Approvals Europe Ltd** (Notified Body Number: **2809**), the product complies with the ATEX directive, Annex III. Quality Assurance Notification complying with Annex IV of the ATEX Directive has been issued by **CML B.V. (2776)**

Berlin, DE, 09.05.2025



By: Elmar Schommer
Regional Manager, EMEA, Product Compliance

EN