

---

## **Performance of MSA Chillgard 5000 according to EN 14624:2012**

We hereby, **MSA Europe GmbH, Schlüsselstrasse 12, 8645 Rapperswil-Jona, CH - Switzerland** declare that the **Chillgard 5000** measuring range of 0-1000 ppm R134A is developed to meet the EN 14624 standard.

We declare that the above described Unit fulfil the follow technical specification according the EN 14624:2012:

- The upper and lower detection limits
- Response times
- Recovery time from expose to large concentrations

As stated in the Operating Manual Chillgard 5000 Refrigerant Monitor.

In case of any modification of the Chillgard 5000, this manufacture declaration will be getting invalid.

Firmware release: 1.18.0224 / GUI 1.18.1000

Berlin, 18.09.2020



Ingmar Bönig  
European Product Compliance Manager

MSA Technologies and Enterprise Services GmbH  
Thiemannstrasse 1  
12059 Berlin