SUBMITTAL DATA SHEET

PSE - CACM Revision B
CONDO PACK THRU THE WALL
SINGLE PACKAGED VERTICAL UNIT

JOB NAME: _____ LOCATION: _____

PURCHASER: _____ ORDER NO: _____

ENGINEER: _____

SUBMITTED TO: _____ FOR: _____

REF: _____

APPROVAL: _____

CONSTRUCTION: _____

SUBMITTED BY: _____ DATE: _____

UNIT DESIGNATION: _____

SCHEDULE NO: _____ MODEL NO: **Select Model**

PRODUCT DATA

COOLING PERFORMANCE

Capacity: _____ BTU/h

EER: _____

Refrigerant: _____

HEATING PERFORMANCE

Heating Capacity

at 240 V: _____ kW

at 208 V: _____ kW

Air Temp Rise

at 240 V: _____ °F

at 208 V: _____ °F

SUPPLY AIR BLOWER PERFORMANCE

Total Supply Air: _____ CFM

Total External Static Pressure: _____ IWC

Motor Rating: _____ HP

ELECTRICAL DATA

Power Supply: _____

Minimum Circuit Ampacity

at 240 V: _____ A

at 208 V: _____ A

Maximum Overload Protection

at 240 V: _____ A

at 208 V: _____ A

UNIT WEIGHT

Unit Shipping Weight: _____ LBS

DIMENSIONS AND CLEARANCES

NOTE ***ENGINEER / ARCHITECT TO CONSULT WITH NAPOLEON ENGINEERING TO DETERMINE BRACKET LOCATION FOR SETTING THE DESIRED DEPTH OF WALL SLEEVE INTO WALL.

CLEARANCES

FRONT	0.25" MIN.
RIGHT SIDE	2" MIN.
LEFT SIDE	0"
BOTTOM	8" from the floor

** A clear and unobstructed passageway (dimension AxB) shall be provided to the unit, in accordance with the requirements of the local authorities having jurisdiction and the National Electrical Code in the United States or CAN/CGA-B149.1 & .2 and the Canadian Electrical Code CSA C22.1 Part 1 (latest edition) in Canada.



* The 32" x 32" unobstructed clearance is required in front of the unit for complete removal of heating and cooling module. Check local building codes for other applicable requirements.