

Rinnai®

Technical Bulletin 143 - DiversiTech Termination Approval for SENSEI™ Tankless Water Heaters


The purpose of this technical bulletin is to announce approval of the 2 in. and 3 in. DiversiTech concentric vent terminations for the following Rinnai SENSEI™ Condensing Tankless Water Heaters:

Certified for Use with Rinnai Tankless Water Heater Models

Residential	Residential (With Pump)	Commercial
RU199i (REU-N3237FF-US) RU180i (REU-N2934FF-US) RU160i (REU-N2530FF-US) RU130i (REU-N2024FF-US)	RUR199i (REU-NP3237FF-US) RUR160i (REU-NP2530FF-US)	CU199i (REU-N3237FFC-US) CU160i (REU-N2530FFC-US)

Installation of the terminations must conform to the Rinnai Installation and Operation Manual that is shipped with the unit, local codes, or in the absence of local codes, with the National Fuel Gas Code, ANSI Z223.1/NFPA 54.

DiversiTech Concentric Vent Termination Part #	Equivalent Vent Length
DiversiTech CVENT-3 (3 in. Exhaust Vent Size)	20 ft (6 m)
DiversiTech CVENT-2 (2 in. Exhaust Vent Size)	
DiversiTech HVENT-2 (2 in. Low Profile Horizontal Vent Kit)	5 ft (1.5 m)
DiversiTech HVENT-3 (3 in. Low Profile Horizontal Vent Kit)	



Sample DiversiTech 2 in. and 3 in. Concentric Vent Termination



Sample DiversiTech 2 in. and 3 in. Low Profile Horizontal Vent Kit

Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269

Toll-Free: 1-800-621-9419 • Phone: 678-829-1700 • www.rinnai.us

©2018 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.