

DECLARATION OF CONFORMITY n°5-385 rev.5

(ISO CEI EN 17050:2005)

CISA S.p.A.

declares under its sole responsibility that the cylinders series:

C2000

artt. 1.0G300.xx.0.xx.xx.xx, 1.0G301.xx.0.xx.xx.xx, 1.0G304.xx.0.xx.xx.xx,
1.0G302.xx.0.xx.xx.xx, 1.0G307.xx.0.xx.xx.xx, 1.0G303.xx.0.xx.xx.xx

subjected to this declaration were successfully tested,
according to the standard:

EN 1303: 2015

REQUIREMENT	4.2	4.3	4.4	4.5	4.6	4.7	4.8	4.9
CLASSIFICATION	6.2	6.3	6.4	6.5	6.6	6.7	6.8	6.9
DIGIT	1	2	3	4	5	6	7	8
CURRENT	1	6	0	1*	0	C	4	0

meanings::

- 6.2: Category of use
- 6.3: Durability
- 6.4: Door mass (0 not applicable)
- 6.5: Fire resistance
- 6.6: Safety (0 not applicable)
- 6.7: Corrosion resistance and temperature
- 6.8: Key related security
- 6.9: Attack resistance

*Test report Lapi 164.0UN0360-13, 60min fire resistance on wooden door 65mm thick, according EN1634-1.

Faenza, 26th Sept 2016

Manager Locks and Key Systems

Fausto Fustini