#### Edge Lit Recessed LED Downlight - Selectable

### **Product Description**

The REL Selectable Edge Lit Downlight offers an attractive aesthetic with a low profile in round and square forms. The CCT selectable, edge-lit technology makes it a practical solution with high performance. Adjustable spring-loaded retention tabs allow a secure fit for easy installation in both new construction and remodel applications. The RELS is an ideal solution for multi-family dwellings such as apartment buildings, condos, townhomes, and commercial applications.

#### Construction

- Cast aluminum housing routes heat away from electrical components
- Edge-Lit technology allows for extremely thin fixture depth
- Adjustable, spring loaded retention tabs ensure secure fixture retention
- Off-board driver minimizes installation height and maximizes fixture life through improved heat management

#### **Optical System**

- Precision engineered optical stack creates uniform light distribution that maximizes lumen output
- Utilizes high performing LEDs with 90+ CRI and an R9 > 50
- Offered with 5CCT selection of 2700K, 3000K, 3500K, 4000K, and 5000K

#### Electrical

- Input voltage of 120VAC
- CCT selector switch located on driver
- Dimmable to 5% with compatible leading edge (TRIAC) or trailing edge (ELV) dimmers
- Operating temperature rating of -4°F to 104°F (-20°C to 40°C)

#### Finish

- White Powder Coat Finish is standard for all models.
- REL3 is available in both White and Black painted finishes.
- For larger-diameter fixtures, Color Trims Accessories are available in Black, Nickel, or Oil-Rubbed Bronze.

#### **Mounting and Installation**

- Spring loaded retention tabs allow for easy installation into ceilings up to 3/4" thick with no need for a recessed housing
- Off-board driver/junction box includes three 1/2" KOs and three-port poke-in connectors
- Paper cutting template included
- Accessory metal rough-in template and frames available
- Accessory extension power cables (2' & 10') available
- For installations where power surge may be possible, NICOR recommends installing additional surge protection at the electrical distribution panel

#### Listings

- cETLus 1598 Classified for wet locations
- Energystar listed
- CA Title 24 compliant (JA8)
- · Certified for direct contact with insulation (IC-Rated)
- Meets Air Tight requirements per ASTM E283
- Compliant with NFPA® 70, NEC® Section 410.16 (A)(3) and 410.16 (C)(5) for closet use
- RoHS Compliant: Free from harmful and hazardous materials
- Meets FCC Part 15, Subpart B, Class B standards for conducted and radiated emissions
- LED lumen maintenance: L70(9k)>54,000 hrs
- LM-79, LM-80 testing performed in accordance with IESNA standards

#### Warranty

- 5-year limited system warranty standard
- Warranty does not cover product failure due to an overvoltage event (power surge)

Project

Catalog

Туре

Date



# RELS

**3", 4", 6", and 8" Edgelit LED Downlight** 550, 600, 900, 1200 lumen





Ordering					
Ordering Informati	on				Example : REL61120SRDWH
Series	Version	Voltage	CCT's	Trim Shape	Trim Color
REL3 (3 inch)	1	120	S (Selectable)	<b>RD</b> (Round)	<b>WH</b> (White)
REL4 (4 inch)				<b>SQ</b> (Square) <sup>1</sup>	<b>BK</b> (Black) <sup>2</sup>
REL6 (6 inch)					
REL8 (8 inch)					

Specifications and dimensions subject to change without notice. Please refer to the website for the most up-to-date information.

1. Square only available for 4" and 6" models.

2. Black painted finish available on REL3 (in addition to White). For larger diameter please refer to the accessories below.

Accessories	accessories sold separately
4" Black Trim Ring	REL4-1-TR-RD-BK
4" Brushed Nickel Trim Ring	REL4-1-TR-RD-NK
4" Oil-Rubbed Bronze Trim Ring	REL4-1-TR-RD-OB
6″ Black Trim Ring	REL6-1-TR-RD-BK
6" Brushed Nickel Trim Ring	REL6-1-TR-RD-NK
6" Oil-Rubbed Bronze Trim Ring	REL6-1-TR-RD-OB
8" Black Trim Ring	REL8-1-TR-RD-BK
8" Brushed Nickel Trim Ring	REL8-1-TR-RD-NK
8" Oil-Rubbed Bronze Trim Ring	REL8-1-TR-RD-OB

Accessories	accessories sold separately
4" White Goof Ring	REL4-1-GR-RD-WH
6" White Goof Ring	REL6-1-GR-RD-WH
2' Extension Cable for RELS	RELS-EXTCABLE-02
10' Extension Cable for RELS	RELS-EXTCABLE-10
Frame for 3", 4", 6" remote driver fixtures	MULTIFRAME-346-1
3" Rough In Flat Template	ROUGHIN-TEMPLATE-3
4" Rough In Flat Template	ROUGHIN-TEMPLATE-4
6" Rough In Flat Template	ROUGHIN-TEMPLATE-6
3", 4", 6" Rough In Flat Template	ROUGHIN-TEMPLATE-346
8" Rough In Flat Template	ROUGHINTEMPLATE-REL8

### Performance Data and Dimming

	Perform	ance Data (Rou	nd)			Perform	ance Data (Squ	are)	
Model Number	CCT	Lumens	Watts	Lumens/Watt	Model Number	ССТ	Lumens	Watts	Lumens/Watt
	2700	553	7.79	71.0		2700	612	10.28	59.5
	3000	587	7.65	76.8		3000	658	10.66	61.8
REL31120SRD** (** = WH or BK)	3500	608	7.52	80.9	REL41120SSQWH	3500	690	10.73	64.3
(	4000	616	7.63	80.7		4000	707	10.79	65.5
	5000	607	7.78	78.1		5000	697	10.84	64.3
	2700	656	10.06	65.2		2700	816	11.98	68.1
	3000	710	10.65	66.6		3000	903	12.59	71.7
REL41120SRDWH	3500	726	10.70	67.9	REL61120SSQWH	3500	945	12.66	74.6
	4000	742	10.74	69.1		4000	967	12.67	76.3
	5000	768	10.64	72.1		5000	956	12.82	74.6
	2700	901	11.75	76.7					
	3000	943	12.27	76.8					
REL61120SRDWH	3500	984	12.44	79.1					
	4000	1013	12.45	81.4			Reco	mmended D	immers*
	5000	1019	12.51	81.5				on Skylark SE	
	2700	1264	17.91	70.6				ron Skylark S	
	3000	1327	17.97	73.8				ron DIVA DV	
REL81120SRDWH	3500	1435	17.51	81.9	Lutron DIVA DVELV-300P			LV-300P	
	4000	1446	17.90	80.8	Lutron MAELV-600			/-600	
	5000	1369	18.56	73.8			I	Lutron PD-10	NXD

\*Not a complete list. Check compatibility before installation.




## **Photometric Data**

## **RELS3-RD**

Input Voltage (VAC)	120
System Level Power (W)	7.7
Delivered Lumens (Lm)	553
System Efficacy (Lm/W)	71.8
Correlated Color Temp (K)	2610
Color Rendering Index (CRI)	92 R9=54
Beam Angle	111
Spacing Criteria	1.27

#### **CCT Data Multiplier** 3000K 1.061 3500K 1.099 4000K 1.114 5000K 1.098



Intensity Summary (Candle Power)				
Mean CP				
196				
195				
189				
177				
159				
135				
106				
73				
40				
12				
0				

Cone of Light Tabulation						
Mounted height	Footcandles	Diameter				
(Feet)	Beam Center	(Feet)				
4	11.7	11.7				
6	5.2	17.5				
8	2.9	23.4				
10	1.9	29.2				
Zonal Lumen Summary						
Zone	Lumens	% of Luminaire				
0-30	151	27.3%				
0-40	127	44.7%				
0-60	435	78.7%				
0-90	553	100%				
90-180	0	0%				
0 190	552	1000%				

553

0-180

90-180

0-180

0% 100%


0%

100%

RELS4-RD
----------

Input Voltage (VAC)	120
System Level Power (W)	10.1
Delivered Lumens (Lm)	656
System Efficacy (Lm/W)	65.0
Correlated Color Temp (K)	2741
Color Rendering Index (CRI)	92 R9=54
Beam Angle	114
Spacing Criteria	1.30

CCT Data Multiplier			
3000K	1.082		
3500K	1.107		
4000K	1.131		
5000K	1.071		



Intensity Summary (Candle Power)				
Angle	Mean CP			
0	223			
5	222			
15	216			
25	202			
35	181			
45	153			
55	120			
65	83			
75	46			
85	13			
90	0			

Cone of Light Tabulation					
Mounted height	Footcandles	Diameter			
(Feet)	Beam Center	(Feet)			
4	13.9	12.4			
6	6.2	18.6			
8	3.5	24.8			
10	2.2	31.0			
Zonal Lumen Summary					
Zone	Lumens	% of Luminaire			
0-30	174	26.6%			
0-40	287	43.7%			
0-60	511	77.9%			
0-90	656	100%			

0


656

## **RELS4-SQ**

Input Voltage (VAC)	120
System Level Power (W)	10.3
Delivered Lumens (Lm)	612
System Efficacy (Lm/W)	59.4
Correlated Color Temp (K)	2784
Color Rendering Index (CRI)	93 R9=57
Beam Angle	109.0
Spacing Criteria	1.24

# CCT Data Multiplier

3000K	1.075
3500K	1.127
4000K	1.155
5000K	1.139



Intensity Summary (Candle Power)		
Angle	Mean CP	
0	222	
5	221	
15	213	
25	196	
35	172	
45	143	
55	110	
65	75	
75	40	
85	11	
90	0	

Con	e of Light Tabulatio	n
Mounted height	Footcandles	Diameter
(Feet)	Beam Center	(Feet)
4	19.3	12.3
6	8.6	18.4
8	4.8	24.5
10	3.1	30.7
Zor	hal Lumen Summar	y
Zor Zone	hal Lumen Summary	% of Luminaire
Zone	Lumens	% of Luminaire
Zone 0-30	Lumens 171	% of Luminaire 27.9%
Zone 0-30 0-40	Lumens 171 277	% of Luminaire 27.9% 45.4%
Zone 0-30 0-40 0-60	Lumens 171 277 484	% of Luminaire 27.9% 45.4% 79.2%

Fixture tested per LM-79-08. Photometric data is of the performance of a representative fixture. Results may vary in the field.




## **Photometric Data**

## **RELS6-RD**

Input Voltage (VAC)	120
System Level Power (W)	11.8
Delivered Lumens (Lm)	901
System Efficacy (Lm/W)	76.4
Correlated Color Temp (K)	2753
Color Rendering Index (CRI)	93 R9=56
Beam Angle	113.8
Spacing Criteria	1.28

#### CCT Data Multiplier 3000K 1.047 3500K 1.092 4000K 1.124 5000K 1.131



Intensity Summary (Candle Power)		
Angle	Mean CP	
0	308	
5	307	
15	296	
25	276	
35	246	
45	207	
55	161	
65	110	
75	59	
85	15	

0

85 90


Con	e of Light Tabulatior	1	
Mounted height (Feet)	Footcandles Beam Center	Diameter (Feet)	
4	19.3	12.3	
6	8.5	18.4	
8	4.8	24.5	
10	3.1	30.7	
Zonal Lumen Summary			

		,
Zone	Lumens	% of Luminaire
0-30	241	26.7%
0-40	396	44%
0-60	704	78.1%
0-90	901	100%
90-180	0	0%
0-180	901	100%

# **RELS6-SQ**

Input Voltage (VAC)	120
System Level Power (W)	12.0
Delivered Lumens (Lm)	816
System Efficacy (Lm/W)	68.0
Correlated Color Temp (K)	2785
Color Rendering Index (CRI)	93 R9=59
Beam Angle	114.2
Spacing Criteria	1.30

CCT Data I	Multiplier
3000K	1.107
3500K	1.158
4000K	1.185
5000K	1.172




	Summary Power)
Angle	Mean CP
0	278
5	278
15	269
25	252
35	226
45	192
55	151
65	105
75	57
85	16
90	0

Cone of Light Tabulation		
Mounted height	Footcandles	Diameter
(Feet)	Beam Center	(Feet)
4	17.4	12.4
6	7.7	18.5
8	4.3	24.7
10	2.8	30.9
Zor	al Lumen Summar	y
<b>Zor</b> Zone	hal Lumen Summary	% of Luminaire
		·
Zone	Lumens	% of Luminaire
Zone 0-30	Lumens 218	% of Luminaire 26.7%
Zone 0-30 0-40	Lumens 218 359	% of Luminaire 26.7% 44%
Zone 0-30 0-40 0-60	Lumens 218 359 638	% of Luminaire 26.7% 44% 78.2%

## **RELS8-RD**

Input Voltage (VAC)	120
System Level Power (W)	17.9
Delivered Lumens (Lm)	1264
System Efficacy (Lm/W)	70.6
Correlated Color Temp (K)	2780
Color Rendering Index (CRI)	93 R9=54
Beam Angle	113.4
Spacing Criteria	1.28

CCT Data Multiplier		
1.050		
1.063		
1.144		
1.083		



Intensity Summary (Candle Power)			
Angle	Mean CP		
0	435		
5	432		
15	418		
25	391		
35	349		
45	296		
55	232		
65	161		
75	88		
85	25		
90	0		

Cone of Light Tabulation					
Mounted height (Feet)	Footcandles Beam Center	Diameter (Feet)			
4	27.2	12.2			
6	12.1	18.3			
8	6.8	24.4			
10	4.3	30.4			
7					

Zonal Lumen Summary					
Lumens	% of Luminaire				
339	26.8%				
557	44.1%				
990	78.3%				
1264	100%				
0	0%				
1264	100%				
	Lumens 339 557 990 1264 0				


Fixture tested per LM-79-08. Photometric data is of the performance of a representative fixture. Results may vary in the field.



Dimensions				
	Fixture	Outer Diameter ( <b>OD</b> )	Fixture Height ( <b>H</b> )	Driver ( <b>LxWxH</b> )
	RELS3 Round	3.8 in Ø (95mm)	1.04 in (26.4mm)	5.1 in x 2.4 in x 1.4 in (130mm x 61mm x 30mm)
	RELS4 Round	4.7in Ø (120mm)	0.87 in (22mm)	
	RELS6 Round	6.7in Ø (170mm)	0.83 in (21mm)	
_	RELS8 Round	8.9in Ø (225mm)	0.83 in (21mm)	4.1in x 2.7 in x 1.4 in (104mm x 69mm x 36mm)
	RELS4 Square	4.7in x 4.7in (120mm)	0.91 in (23mm)	
	RELS6 Square	6.7in x 6.7in (170mm)	0.91 in (23mm)	

## **RELS-SQ**





This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

NOTE: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

Reorient or relocate the receiving antenna.
Increase the separation between the equipment and receiver.

-Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.

-Consult the dealer or an experienced radio/TV technician for help.

