



Technical Bulletin 159 - SENSEI™ CSA Certification and ULC S636 PVC Venting

Purpose: The purpose of this Technical Bulletin is to communicate the following Rinnai SENSEI™ Tankless Water Heaters are CSA certified and approved for installation with ULC S636 approved PVC venting.

The models below have a maximum vent temperature of 140°F (60°C).

SENSEI™ Tankless Water Heater	Trade Number
Residential Models:	
RU199i	REU-N3237FF-US
RU180i	REU-N2934FF-US
RU160i	REU-N2530FF-US
RU130i	REU-N2024FF-US
RU199e	REU-N3237W-US
RU180e	REU-N2934W-US
RU160e	REU-N2530W-US
RU130e	REU-N2024W-US
Residential with Pump Models:	
RUR199i	REU-NP3237FF-US
RUR160i	REU-NP2530FF-US
RUR199e	REU-NP3237W-US
RUR160e	REU-NP2530W-US
Commercial Models:	
CU199i	REU-N3237FFC-US
CU160i	REU-N2530FFC-US
CU199e	REU-N3237WC-US
CU160e	REU-N2530WC-US

WARNING

The installation must conform with local codes or, in the absence of local codes, with the National Fuel Gas Code, ANSI Z223.1/NFPA 54, or the Natural Gas and Propane Installation Code, CSA B149.1.

Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269

Toll-Free: 1-800-621-9419 • Phone: 678-829-1700 • www.rinnai.us

©2019 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.