



## **Technical Bulletin 136 - 4" PVC/CPVC Approval for Rinnai Boilers**

The purpose of this technical bulletin is to announce the certification of 4" Solid Core Schedule 40 PVC and CPVC for use with Rinnai Condensing Boilers.

### MAXIMUM EQUIVALENT VENT RUN

BOILER MODEL	VENT TYPE
	4" PVC/CPVC
E50CR	100 Ft (30 m)
E75CR	
E60SR	
E85SR	
Q85S	
QP85	



Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269

Toll-Free: 1-800-621-9419 • Phone: 678-829-1700 • [www.rinnai.us](http://www.rinnai.us)

©2017 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.