

Recessed pendent sprinklers

Project information

|                                |                 |
|--------------------------------|-----------------|
| Job name:                      | Location:       |
| Engineer:                      | Date submitted: |
| Contractor:                    | Submitted by:   |
| Manufacturer's representative: | Approved by:    |

Technical data

|                         |                                     |
|-------------------------|-------------------------------------|
| Temp/pressure ratings   | 73 °F (23 °C) at 160 psi (11 bar)   |
|                         | 180 °F (82 °C) at 100 psi (6.9 bar) |
|                         | 200 °F (93 °C) at 80 psi (5.5 bar)  |
| Prop 65 label required? | Yes                                 |



| Part name                                                | Part no.  | Weight per UOM [lbs/UOM] |
|----------------------------------------------------------|-----------|--------------------------|
| LF Recessed Pendent Sprinkler, 155F, 3.0 K-factor, White | LF73000WH | 0.15                     |
| LF Recessed Pendent Sprinkler, 175F, 3.0 K-factor, White | LF73001WH | 0.15                     |
| LF Recessed Pendent Sprinkler, 155F, 4.9 K-factor, White | LF74900WH | 0.15                     |
| LF Recessed Pendent Sprinkler, 175F, 4.9 K-factor, White | LF74901WH | 0.15                     |

| Installation | Related applications          |
|--------------|-------------------------------|
| -            | AquaSAFE™ Fire Safety Systems |

| Footnotes | Contact information                                                                                                                                                                                                               |
|-----------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| -         | <div>Uponor Inc.<br/>5925 148th Street West<br/>Apple Valley, MN 55124<br/>T 800.321.4739<br/>F 952.891.2008</div> <div>Uponor Ltd.<br/>6510 Kennedy Road<br/>Mississauga, ON L5T 2X4<br/>T 888.594.7726<br/>F 800.638.9517</div> |