

**GE Current, a Daintree company**

1975 Noble Road  
E. Cleveland, OH 44112  
USA

## Certificate of Analysis

### Reporting Analytical Lab

Alpha Analytical Labs  
Westborough, MA 01581-1019

DESCRIPTION: **T8 Ecolux Fluorescent Lamps - 4'**  
MODEL: **F32T8/SP35/ECO**

### Test

**Toxicity Characteristic Leaching Procedure (TCLP)  
for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste  
Physical/Chemical Methods, SW-846**

**Tested in accordance with ANSI Standard, ANSI/NEMA C78. LL1256-2003,  
"Procedures for Linear Fluorescent Lamp Sample Preparation and the TCLP."**

### TCLP Maximum Allowable Concentration for Mercury

- **0.200 mg/Liter (USA)**
- **0.100 mg/Liter (Canada)**

NUMBER OF LAMPS: **10**

### Result Summary

Average Result: **0.047 mg/L**

Standard Deviation: **0.007**

90% Confidence Limit: **0.056 mg/L**

TCLP RESULT: **PASSED USA & CANADA**