

GE Current, a Daintree company

1975 Noble Road
E. Cleveland, OH 44112
USA

Certificate of Analysis

Reporting Analytical Lab

LAB: **Multiple Laboratories**

ADDRESS:

DATE: **February-05**

DESCRIPTION: **T8 Ecolux, SP Fluorescent Lamps - U6**

MODEL: **F32T8/SP/U/6/ECO**

Test

**Toxicity Characteristic Leaching Procedure (TCLP)
for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste
Physical/Chemical Methods, SW-846**

**Tested in accordance with NEMA Standard, NEMA LL 5,
"Procedures for U-Shaped Fluorescent Lamp Sample Preparation and the TCLP."**

TCLP Maximum Allowable Concentration for Mercury

- **0.200 mg/Liter (USA)**
- **0.100 mg/Liter (Canada)**

NUMBER OF LAMPS: **82**

Result Summary

Average Result: **0.150 mg/Liter**

Standard Deviation: **0.03**

90% Confidence Limit: **0.155 mg/Liter**

TCLP RESULT: **PASSED – USA**