

**GE Current, a Daintree company**

1975 Noble Road  
E. Cleveland, OH 44112  
USA

## Certificate of Analysis

### Reporting Analytical Lab

**Alpha Analytical Labs**  
Westborough, MA 01581-1019

DESCRIPTION: **T8 Ecolux Fluorescent Lamps - 4'**  
MODEL: **F32T8/SPX41/ECO**

### Test

**Toxicity Characteristic Leaching Procedure (TCLP)**  
**for Mercury EPA Method 1311 of Test Methods for Evaluating Solid Waste**  
**Physical/Chemical Methods, SW-846**

**Tested in accordance with ANSI Standard, ANSI/NEMA C78. LL1256-2003,**  
**"Procedures for Linear Fluorescent Lamp Sample Preparation and the TCLP."**

### TCLP Maximum Allowable Concentration for Mercury

- **0.200 mg/Liter (USA)**
- **0.100 mg/Liter (Canada)**

NUMBER OF LAMPS: **7**

### Result Summary

Average Result: **0.060 mg/L**

Standard Deviation: **0.005**

90% Confidence Limit: **0.063 mg/L**

TCLP RESULT: **PASSED USA & CANADA**