

EXL1v2 | LED EMERGENCY EXIT SIGN

INSTALLATION INSTRUCTIONS

MODELS: EXL120UNVWHS2

WARNING: FAILURE TO FOLLOW THESE INSTRUCTIONS AND WARNINGS MAY RESULT IN DEATH, SERIOUS INJURY OR SIGNIFICANT PROPERTY DAMAGE. For your protection, read and follow these warnings and instructions carefully before installing or maintaining this equipment. These instructions do not attempt to cover all installation and maintenance situations. If you do not understand these instructions or additional information is required, contact or your local distributor.


WARNING: RISK OF ELECTRIC SHOCK - NEVER CONNECT TO, DISCONNECT FROM, OR SERVICE WHILE EQUIPMENT IS ENERGIZED.


WARNING: RISK OF FIRE. Lamps are hot. Keep combustible material away from hot parts. Observe lamp manufacture's warnings, recommendations and restrictions on lamp operation and maintenance. Make sure lamps are correctly installed.


CAUTION: The battery in this unit may not be fully charged. After powering the unit, charge the battery for at least 24 hours, then normal operation of this unit should take effect. To check, press the TEST button. The lamps on the unit should turn on. (Refer to OPERATION BATTERY BACK UP for more testing information)

IMPORTANT SAFEGUARDS: When using electrical equipment, basic safety precautions should always be followed, including the following:

- Do not use outdoors. Suitable for use in 50°F to 104°F (10°C to 40°C) indoor damp locations.
- · Consult local building code for approved wiring and installation.
- Disconnect AC power before servicing and installation.
- Do not mount near gas or electric heaters.
- Do not use this equipment for anything other than its intended use.
- The use of accessory equipment not recommended by the manufacturer will void product listing and warranty and may cause an unsafe condition.
- Any service on this equipment should be performed by qualified personnel only.
- Equipment should be mounted in locations and at heights where it will not be subject to tampering by unauthorized personnel.
- Use caution when servicing batteries.
- Cap unused wires with enclosed wire nuts or other approved method.
- · Make sure wire terminations are secure and leads are properly tucked in appropriate wire channels.









EXL1v2 | LED EMERGENCY EXIT SIGN

INSTALLATION INSTRUCTIONS

MODELS: EXL120UNVWHS2


NOTE: EXIT ships standard RED. Refer to Toggle Switch section for GREEN LED configuration.

WALL MOUNT INSTALLATION

- 1. Remove EXIT stencil faceplate from housing. Remove RED lens from faceplate (see Fig. A). Set aside.
- 2. Drill or knock out appropriate knockouts on back plate to fit junction box mounting points.
- 3. Drill or knock out center hole in back plate for EXIT supply wire leads.
- Route EXIT input wires though center hole of the back plate and make wiring connection. For 120V, use black and white wires and for 277V, use red and white wires.
- 5. Secure back plate to junction box (hardware not included).
- 6. Toggle the switchable to select GREEN, if applicable (see Fig. C).
- 7. Connect battery.
- Remove knockout chevron(s) on faceplate, as needed. Re-insert RED lens to faceplate (see Fig. A) (or GREEN if applicable, see Fig. B). Secure EXIT stencil faceplate back onto housing.
- 9. Apply continuous AC power, LED indicator will be RED.
- 10. Press "TEST" button to check operation. (See OPERATION BATTERY BACK UP for testing procedures).

CEILING OR END MOUNT INSTALLATION


- Remove EXIT stencil faceplate from housing. Remove RED lens from faceplate (see Fig. A). Set aside.
- 2. Place screws (provided) in holes on the canopy.
- 3. Remove the desired mounting hole plug located on the frame HOLE PLUGREMOVE FOR of the sign. For ceiling mount, hole plug will be located on the CEILING MOUNT top of the housing. For end mount, hole plug will be located on the side of the housing.
- 4. Place canopy tab through the mounting hole of the housing until the flat portion of the canopy is touching the housing frame. Lock the canopy into place by sliding the canopy, without turning, toward smaller end of the mounting hole until the tab is fully engaged and locked into place. Once canopy is in the locked position there will not be any side-to-side movement of the canopy.
- 5. Route EXIT input wires through canopy and through metal mounting plate.
- 6. Make wiring connection. For 120V, use black and white wires and for 277V, use red and white wires.
 - **WARNING:** Properly insulate the unused lead with a wire nut (provided) or other approved means.
- 7. Push wire connections into the J-Box. Secure mounting plate to junction box (hardware not included).
- 8. Secure the canopy to the steel mounting plate with screws installed in step 2.
- 9. Toggle the switchable to select GREEN, if applicable (see Fig. C).
- Remove knockout chevron(s) on faceplate, as needed. Re-insert RED lens to faceplate (see Fig. A)(or GREEN if applicable, see Fig. B). Secure EXIT stencil faceplate back onto housing.
- 11. Connect battery.
- 12. Apply continuous AC power, LED indicator will be RED.
- Press "TEST" button to check operation.
 (See OPERATION BATTERY BACK UP for testing procedures).



WIRING DIAGRAM:

MOUNTING PLATE

Recommended 4"



MOUNTING PLATE



EXL1v2 | LED EMERGENCY EXIT SIGN

INSTALLATION INSTRUCTIONS

MODELS: EXL120UNVWHS2

OPERATION (BATTERY BACKUP)

- 1. Apply AC power to the unit. The LED indicator will be RED.
- 2. After the battery has been left to charge for 24 hours, test the unit by pushing the switch. The LED indicator turns OFF and the LED board stays ON.
- 3. When the switch is released, the LED indicator turns back to RED and the LED board stays ON.

MAINTENANCE

Caution: Always turn off AC power to the equipment before servicing. Serving should be performed only by a qualified service technician. Use only NICOR supplied replacement parts.

BATTERY: The battery supplied with the EXL1v2 model requires no maintenance. However, it should be tested periodically and replaced when it no longer operates the connected sign for the duration of a 30-second or 90-minute test. The battery supplied in this sign has a typical life of 5 years when used in a normal ambient temperature of 72° F.

SAVE THESE INSTRUCTIONS

IMPORTANT CODE COMPLIANCE INFORMATION

In accordance with NFPA 101 (current Life Safety Code), documented testing of your emergency lighting system must be tested monthly for a minimum of 30 seconds and annually for 90 minutes. Refer to your local codes for any additional requirements that may apply.